

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1571:100 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Tomar Electronics Inc., 2100 W. Obispo Avenue, Gilbert, AZ 85233
Contact: Thomas Sikora (480) 497-4400 Fax (480) 497-4416

DESIGN: Models 4375-120/240 and 4375-1274 non-hearing impaired strobe lights. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: Electrical: 12-74 VDC, 120-240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use in hazardous locations Class I, Division 2, Group A, B, C and D; Class II, Division 2, Group F and G and Class III. Suitable for outdoor use.

NOTE: Not approved for the hearing impaired applications.

07-16-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager